


DEPUTY MINISTRY OF TOURISM

HOTEL ESTABLISHMENTS WITH FACILITIES FOR PEOPLE WITH ACCESS NEEDS

Name of the establishment:	TETYK		
Category:	HOTEL APARTMENTS		
Website:	www.tetyk.com.cy		
Address:	6 Thaleias Str., Paralimni		
Date of inspection:	3/11/17		
Facilities			
1	Parking Facilities for persons with disabilities		
1.1	Number of available parking spaces for persons with disabilities? (min. dimensions 3.30X5m)	2	
1.2	Are they near the main entrance?	YES	
1.3	Is there adequate marking of parking places (vertical signpost)?	YES	
1.4	Is there access to entrance via an unobstructed accessible route?	YES	
1.5	Is the car park area surface paved (no gravel)?	YES	
Remarks: - Dimensions of parking facilities for persons with disabilities are 3.30m x 4.00m.			
2	Entrance		
2.1	Does the entrance door permit easy access?	YES	
2.2	Number of steps between ground level and entrance?	4	
2.3	Is there a supporting handrail at the staircase entrance?	YES	
2.4	Is there a ramp at the entrance?	YES	
	2.4.1	Length of ramp?	8.80m
	2.4.2	Slope of ramp?	7%
	2.4.3	Is there a supporting handrail at the ramp?	YES
	2.4.4	Is the ramp floor surface non-slippery?	YES
Remarks: - There is an elevated difference of 0.02m at the entrance. - There is a supporting handrail (only) on one side only.			

3	Outdoor common use areas			
	3.1	Are there any steps in main common use outdoor areas and how many?	YES	2+2
	3.2	Can a wheelchair maneuver freely in most of the outdoor areas?	YES	
	3.3	Is there a swimming-pool?	YES	
	3.4	Is there a mechanism for hoisting persons with disabilities in/out of the swimming-pool?		NO
	3.5	Is there a restroom facility with shower(s) and changing room(s) by the outdoor swimming-pool for use by persons with disabilities?		NO
	3.6	Is there adequate access to the beach for persons with disabilities?		NO
	3.7	Does the unit provide appropriate wheelchairs for use on the beach?		NO
	3.8	Does the unit provide appropriate wheelchairs for use in seawater?		NO
Remarks: - (From the main building to the swimming pool there are 3 ramps with 6% slope each.) There are 3 ramps with a 6% slope each from the main building to the swimming pool.				
4	Indoor common areas			
	4.1	Are there indoor elevated areas?	YES	
	4.1.1	Number of steps?		4
	4.1.2	Provision of ramps to facilitate access between ground and elevated areas?	YES	
	4.1.3	Length of ramp?		4.30m
	4.1.4	Is there a supporting handrail for ramp?	YES	
	4.1.5	Slope of the ramp?		7%
	4.2	Is there a reception area counter/desk for use by persons with disabilities (i.e. 80cm height)?		NO
	4.3	Restaurant	YES	
	4.3.1	Is there at least one height-adjustable table in dining room?		NO
	4.3.2	Height of tables in dining rooms?		0.72m
	4.3.3	Are the tables in dining rooms free from obstacles (e.g. large bases) to allow a person in a wheelchair to eat comfortably?	YES	
Remarks: - The ramp of the indoor common areas (from the lobby to the reception desk) is as the (below) diagram below:				
 <p>The diagram consists of a rectangular box on the left containing the text '4,30m. slope 7%'. An arrow points from the right side of this box to a curved, semi-circular shape representing a reception desk or counter.</p>				
5	Common use area restroom/sanitary facilities			
	5.1	Accessible toilet booths for use by persons with disabilities?	YES	
	5.2	Dimensions (mXm) of toilet facilities?		1.95 x 1.90m

5.3	Does the toilet door open outwards?		YES	
5.4	Are there supporting handrails on either side of toilet bowl?		YES	
	5.4.1	Is there a horizontal handrail on the sidewall (if the toilet bowl is situated 50cm from the sidewall)?	YES	
	5.4.2	Is there a drop-down rail at the unobstructed side of toilet?	YES	
5.5	Wash basin			
	i	Wash basin without stand?	YES	
	ii	Adjustable height?		NO
	iii	Height of wash basin?	0.60m	
	iv	Is there an unobstructed access below wash basin for wheelchair users?	YES	
Remarks: <ul style="list-style-type: none"> - The accessible common area restroom/sanitary facilities door is 0,90m. wide and opens outwards. - The accessible toilet booth is within the restroom complex of the common (restroom) area. (In the accessible toilet booth there are 2 drop-down rails.) - There are 2 drop-down rails in the accessible toilet booth. 				
6	Lifts/Elevators			
6.1	Dimensions (mXm) of lift?		??	
6.2	Width (cm) of lift entrance with door(s) open?		??	
Remarks:				
7	Is the corridor to the rooms/apartments carpeted?		YES	
Remarks: <ul style="list-style-type: none"> - Carpet and ceramic. 				
8	Rooms/ apartments for people with special access needs –Specify actual Door No(s): 007			
8.1	Number of rooms/ apartments for use by persons with disabilities		1	
8.2	Does the entrance to room/ apartment have a minimum unobstructed width of 85cm?		YES	
8.3	Is the entrance door easy to open?		YES	
8.4	Width of room/ apartment anteroom		0.90m	
8.5	Is the floor of the bedroom/ apartment carpeted?			NO
8.6	Is there sufficient unobstructed wheelchair turning / maneuvering space (minimum 1.5X1.5 m) in the room?		YES	
8.7	Are there audible emergency alarms?		YES	
8.8	Are there visible emergency alarms?			NO

8.9	Is the room's/ apartment's closet at a suitable height for use by persons with disabilities?			NO
8.10	Is there unobstructed non-elevated balcony access for wheelchair use?		YES	
8.11	Is there elevated difference with the balcony? YES		Height? 0.025m	
8.12	Room/ apartment restroom/sanitary facilities			
	8.12.1	Entry door width?	0.85m	
	8.12.2	Does the entry door open outwards / or does it slide?	YES	
	8.12.3	Is there a horizontal door shutting bar mounted to the inside surface of the entry door?		NO
	8.12.4	Dimensions (mXm) of restroom?	2.66 x 2.76m	
	8.12.5	Is there unobstructed space of minimum 80cm width by the side of toilet bowl for easy transfer from wheelchair?	YES	
	8.12.6	Is there an emergency alarm pull cord?		NO
	8.12.7	Distance from toilet bowl to nearest sidewall?	0.45m	
	8.12.8	Grab handling rails		
	i	Is there a mounted horizontal handrail on the sidewall (if the toilet bowl is situated 50cm from the sidewall)?	YES	
	ii	Is there a drop-down rail at the unobstructed approach side of the toilet bowl?	YES	
	iii	Where the distance of the toilet bowl from the sidewall is greater than 50cm, is there a second drop-down rail?	YES	
	8.12.9	Wash basin		
	i	Wash basin without stand?	YES	
	ii	Adjustable height?		NO
	iii	Height of wash basin?	0.65m	
	iv	Is there an unobstructed access below wash basin for wheelchair users?	YES	
	v	Is there an easy to reach mixer/water tap?	YES	
	8.12.10	Shower/ Bathtub		
	i	Is the shower floor at the same level as the floor?	YES	
	ii	Is there a drop-down seat in the shower? If the above answer is YES: Is the height adjustable? NO Height? 0.48m	YES	
	iii	Is there any other type of seat for people who cannot stand?		NO
		If YES, is the height adjustable? NO	Height? N/A	
	iv	Are there any shower grab rails?	YES	
	v	Is there a bathtub?		NO
	vi	Does the unit provide appropriate adjustable seats for use in the bathtub?	N/A	
	vii	Are there any grab-rails in the bathtub?	N/A	

		viii	Is there provision for a bath wheelchair upon request?		NO
		ix	Is there a hoist mechanism on the ceiling?		NO
Remarks: <ul style="list-style-type: none"> - The apartment entrance door is 0,88m. wide. - The (room's) bedroom closet has a hanging rail at a height of 1.56m. 					
General comments:					