



| (A) GENERAL SITE/BUILDING INFORMATION | | | |
|--|---|-------------------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| A.01 | Natural Features | Flat Landscape/Sandy Beach | P.01.1-2 |
| A.02 | Receptionist | No | |
| A.03 | Qualified Singer / Languages Spoken | No | |
| A.04 | Site Access | Pedestrian/ Wheel Chair/ V | |
| A.05 | Parking Area Access | Free | |
| A.06 | Drop Off Point | Not Designated | P.02 |
| A.07 | Onsite Disabled Parking Spaces (3.30x5.00m) | 2 - (3.30X5.00m) | P.03 |
| A.08 | Onsite Wheelchair-Accessible Vehicle Parking | No | P.04 |
| A.09 | On-Street Disabled Parking (2.70x5.00m) | No | P.05 |
| A.10 | Access Ramps | Yes(More info in part D) | P.06.1-9 |
| A.11 | Lifting Platforms | No | P.07 |
| A.12 | Disabled Bathrooms-Dimensions/ Door width | 3-(2.00x1.90m)/≥90cm | P.08.1-5 |
| A.13 | Disabled Elevators | No(More info in part C) | P.09 |
| A.14 | Tactile Site/Building Guidance | No(More info in part G) | |
| A.15 | Braille Writing System Signage/Tactile Diagrams | No(More info in part H) | |
| A.16 | Hearing/Speech Impaired Communication Syst. | No(More info in part F) | |
| A.17 | Emergency Alerting Systems | No (Audible & Visual) | |
| A.18 | Staircase Disabled Emergency Waiting Point | N/A | |
| A.19 | Surface Materials – Parking Area | Asphalt | P.10 |
| A.20 | Surface Materials – General Beach Area | Sand/Wood/Concrete | P.11.1-3 |
| A.21 | Surface Materials – Seating Area | Sand/Wood | P.12.1-3 |
| A.22 | Surface Materials – Water Fountain Area | Decking (More info in part B) | P.13 |
| A.23 | Surface Materials – Bar-B-Que Area | N/A (More info in part B) | P.14 |
| A.24 | Surface Materials – Playground Area | N/A (More in part B) | P.15 |
| A.25 | Drain Covers Types | No(See Photos) | P.16 |
| A.26 | Indoor Light Intensity(LUX) | INA | |
| A.27 | Outdoor Light Intensity (LUX) | INA | |



| (B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION | | | |
|---|--|------------------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| B.01 | Special Category Type Site/Building | Recreational Facility | |
| B.02 | Ticket Counter Height/Knee Space (70cm/60cm) | N/A | P.17 |
| B.03 | Ticket Counter Area (r ≥1.50m) or Dimensions | N/A | |
| B.04 | Inclusive Furnishings | No | P.18 |
| B.05 | Inclusive Furnishings Location | N/A | |
| B.06 | Disabled Friendly Water Fountains | No | P.13 |
| B.07 | Disabled Friendly Bar-B-Que | No | P.14 |
| B.08 | Playground Area Disabled Access | N/A | P.15 |
| B.09 | Special Needs Playground Equipment | No | P.19 |
| B.10 | Trash Receptacles Area Access | Accessible/Difficult Access | P.20 |
| B.11 | Disabled Friendly Trash Receptacles | No | P.21 |
| B.12 | Recycle Receptacles Area Access | Accessible/Difficult Access | P.22 |
| B.13 | Disabled Friendly Recycled Receptacles | No | P.23 |
| B.14 | Beach Area Signage | Partial | P.24 |
| B.15 | Canteen Counter Height | N/A | P.25 |
| B.16 | Public Showers | Accessible/Difficult Access | P.26.1-3 |
| B.17 | Public Change Rooms | N/A | P.27 |
| B.18 | Inclusive Outdoor Gym | Difficult Access | P.28.1-2 |
| B.19 | Beach Area Disabled Access | Accessible/ Difficult Access | P.29.1-6 |
| B.20 | Mobi-Chair Floating Beach Wheelchair | Yes | P.30 |
| B.21 | Coastal Walkway (Slope-Length x Width) | 0-5%- ≥1.50m x 2.50m | P.31 |



| (D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%) | | | |
|--|---|--------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| D.01 | Access Ramp Location | Parking Area | P.06.1-3 |
| D.02 | Rain Protection System | No | |
| D.03 | Number of Inclined Planes | 2 | |
| D.04 | Number of intermediate Level Landings | 1 | |
| D.05 | Top Landing Dimensions (Length x Width) | ≥1.50m 1.60m | |
| D.06 | Top Landing Tactile Warning Strip | No | |
| D.07 | 1 st Inclined Plane (Slope-Length x Width) | 5%-10.0m x 1.40m | |
| D.08 | 1 st Inclined Plane Handrails information | One Side | |
| D.09 | 1 st Inclined Pln Handrails Height (70cm & 90cm) | 70cm & 90cm | |
| D.10 | 1 st Inclined Plane - Width between Handrails | N/A | |
| D.11 | 1 st Inclined Plane Edge Protection | Yes | |
| D.12 | 1 st intermediate Level Landing (Length x Width) | 1.50m x 1.40m | |
| D.13 | 1 st Landing Handrails information | One Side | |
| D.14 | 1 st Landing Edge Protection | Yes | |
| D.15 | 2 nd Inclined Plane (Slope-Length x Width) | 5% - 10.0m x 1.40m | |
| D.16 | 2 nd Inclined Plane Handrails information | One Side | |
| D.17 | 2 nd Inclined Pln Handrails Height (70cm & 90cm) | 70cm & 90cm | |
| D.18 | 2 nd Inclined Plane - Width between Handrails | N/A | |
| D.19 | 2 nd Inclined Plane Edge Protection | Yes | |
| D.20 | Bottom Landing Dimensions (Length x Width) | 1.50m x 1.40m(OOS) | |
| D.21 | Bottom Landing Tactile Warning Strip | No | |



| (D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%) | | | |
|--|---|--------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| D.01 | Access Ramp Location | Bathroom Area | P.06.4 |
| D.02 | Rain Protection System | No | |
| D.03 | Number of Inclined Planes | 2 | |
| D.04 | Number of intermediate Level Landings | 1 | |
| D.05 | Top Landing Dimensions (Length x Width) | ≥1.50m 1.40m | |
| D.06 | Top Landing Tactile Warning Strip | No | |
| D.07 | 1 st Inclined Plane (Slope-Length x Width) | 5%-5.00m x 1.40m | |
| D.08 | 1 st Inclined Plane Handrails information | One Side | |
| D.09 | 1 st Inclined Pln Handrails Height (70cm & 90cm) | 65cm & 85cm | |
| D.10 | 1 st Inclined Plane - Width between Handrails | N/A | |
| D.11 | 1 st Inclined Plane Edge Protection | Yes | |
| D.12 | 1 st intermediate Level Landing (Length x Width) | 1.40m x 1.30m | |
| D.13 | 1 st Landing Handrails information | One Side | |
| D.14 | 1 st Landing Edge Protection | Yes | |
| D.15 | 2 nd Inclined Plane (Slope-Length x Width) | 6% - 3.00m x 1.30m | |
| D.16 | 2 nd Inclined Plane Handrails information | One Side | |
| D.17 | 2 nd Inclined Pln Handrails Height (70cm & 90cm) | 65cm & 85cm | |
| D.18 | 2 nd Inclined Plane - Width between Handrails | N/A | |
| D.19 | 2 nd Inclined Plane Edge Protection | Yes | |
| D.20 | Bottom Landing Dimensions (Length x Width) | 1.50m x 1.30m | |
| D.21 | Bottom Landing Tactile Warning Strip | No | |



| (D) ACCESS RAMPS DETAILS – RAMP #03 (≥5%) | | | |
|--|---|----------------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| D.01 | Access Ramp Location | Parking/Coastal Walkway A. | P.06.5 |
| D.02 | Rain Protection System | No | |
| D.03 | Number of Inclined Planes | 2 | |
| D.04 | Number of intermediate Level Landings | 1 | |
| D.05 | Top Landing Dimensions (Length x Width) | ≥1.50m 1.50m | |
| D.06 | Top Landing Tactile Warning Strip | No | |
| D.07 | 1 st Inclined Plane (Slope-Length x Width) | 2%-3.60m x 1.40m | |
| D.08 | 1 st Inclined Plane Handrails information | One Side | |
| D.09 | 1 st Inclined Pln Handrails Height (70cm & 90cm) | 65cm & 85cm | |
| D.10 | 1 st Inclined Plane - Width between Handrails | N/A | |
| D.11 | 1 st Inclined Plane Edge Protection | Yes | |
| D.12 | 1 st intermediate Level Landing (Length x Width) | 1.40m x 1.30m | |
| D.13 | 1 st Landing Handrails information | One Side | |
| D.14 | 1 st Landing Edge Protection | Yes | |
| D.15 | 2 nd Inclined Plane (Slope-Length x Width) | 7% - 9.00m x 1.30m | |
| D.16 | 2 nd Inclined Plane Handrails information | One Side | |
| D.17 | 2 nd Inclined Pln Handrails Height (70cm & 90cm) | 65cm & 85cm | |
| D.18 | 2 nd Inclined Plane - Width between Handrails | N/A | |
| D.19 | 2 nd Inclined Plane Edge Protection | Yes | |
| D.20 | Bottom Landing Dimensions (Length x Width) | 1.50m x 1.50m | |
| D.21 | Bottom Landing Tactile Warning Strip | No | |



| (D) ACCESS RAMPS DETAILS – RAMP #04(≥5%) | | | |
|---|---|----------------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| D.01 | Access Ramp Location | Public Showers/ Beach Area | P.06.6-7 |
| D.02 | Rain Protection System | No | |
| D.03 | Number of Inclined Planes | 5 | |
| D.04 | Number of intermediate Level Landings | 4 | |
| D.05 | Top Landing Dimensions (Length x Width) | ≥1.50m x 1.40m | |
| D.06 | Top Landing Tactile Warning Strip | No | |
| D.07 | 1 st Inclined Plane (Slope-Length x Width) | 5%-9.00m x 1.40m | |
| D.08 | 1 st Inclined Plane Handrails Information | One Side | |
| D.09 | 1 st Inclined Pln Handrails Height (70cm & 90cm) | 67cm & 87cm | |
| D.10 | 1 st Inclined Plane - Width between Handrails | N/A | |
| D.11 | 1 st Inclined Plane Edge Protection | Yes | |
| D.12 | 1 st intermediate Level Landing (Length x Width) | 3.00m x 1.40m | |
| D.13 | 1 st Landing Handrails Information | One Side | |
| D.14 | 1 st Landing Edge Protection | Yes | |
| D.15 | 2 nd Inclined Plane (Slope-Length x Width) | 5%-9.00m x 1.40m | |
| D.16 | 2 nd Inclined Plane Handrails information | One Side | |
| D.17 | 2 nd Inclined Pln Handrails Height (70cm & 90cm) | 67cm & 87cm | |
| D.18 | 2 nd Inclined Plane - Width between Handrails | N/A | |
| D.19 | 2 nd Inclined Plane Edge Protection | Yes | |
| D.20 | 2 nd intermediate Level Landing (Length x Width) | 3.00m x 1.40m | |
| D.21 | 2 nd Landing Handrails Information | One Side | |
| D.22 | 2 nd Landing Edge Protection | Yes | |
| D.23 | 3 rd Inclined Plane (Slope-Length x Width) | 5%-9.00m x 1.40m | |
| D.24 | 3 rd Inclined Plane Handrails information | One Side | |
| D.25 | 3 rd Inclined Pln Handrails Height (70cm & 90cm) | 67cm & 87cm | |
| D.26 | 3 rd Inclined Plane - Width between Handrails | N/A | |
| D.27 | 3 rd Inclined Plane Edge Protection | Yes | |
| D.28 | 3 rd intermediate Level Landing (Length x Width) | 3.00m x 1.40m | |
| D.29 | 3 rd Landing Handrails Information | One Side | |
| D.30 | 3 rd Landing Edge Protection | Yes | |
| D.31 | 4 th Inclined Plane (Slope-Length x Width) | 5%-9.00m x 1.40m | |
| D.32 | 4 th Inclined Plane Handrails information | One Side | |
| D.33 | 4 th Inclined Pln Handrails Height (70cm & 90cm) | 67cm & 87cm | |
| D.34 | 4 th Inclined Plane - Width between Handrails | N/A | |
| D.35 | 4 th Inclined Plane Edge Protection | Yes | |
| D.36 | 4 th intermediate Level Landing (Length x Width) | 3.00m x 1.40m | |
| D.37 | 4 th Landing Handrails Information | One Side | |
| D.38 | 4 th Landing Edge Protection | Yes | |
| D.39 | 5 th Inclined Plane (Slope-Length x Width) | 5%-9.00m x 1.40m | |
| D.40 | 5 th Inclined Plane Handrails information | One Side | |
| D.41 | 5 th Inclined Pln Handrails Height (70cm & 90cm) | 67cm & 87cm | |



| | | | |
|------|--|---------------|--|
| D.42 | 5 th Inclined Plane - Width between Handrails | N/A | |
| D.43 | 5 th Inclined Plane Edge Protection | Yes | |
| D.44 | Bottom Landing Dimensions (Length x Width) | 1.50m x 1.50m | |
| D.45 | Bottom Landing Tactile Warning Strip | No | |

| (D) ACCESS RAMPS DETAILS – RAMP #05 (≥5%) | | | |
|--|---|---------------------------|-------------|
| ITEM# | PROVISION DESCRIPTION | CHECKLIST | PHO# |
| D.01 | Access Ramp Location | Coas. Walkway/ Beach Area | P.06.8-9 |
| D.02 | Rain Protection System | No | |
| D.03 | Number of Inclined Planes | 1 | |
| D.04 | Number of intermediate Level Landings | 0 | |
| D.05 | Top Landing Dimensions (Length x Width) | ≥1.50m x 2.20m | |
| D.06 | Top Landing Tactile Warning Strip | No | |
| D.07 | Inclined Plane (Slope-Length x Width) | 11-15% - 21.00m x 2.20m | |
| D.08 | Inclined Plane Handrails information | Both Sides | |
| D.09 | Inclined Plane Handrails Height (70cm & 90cm) | 65cm & 90cm | |
| D.10 | Inclined Plane - Width between Handrails | 2.20m | |
| D.11 | Inclined Plane Edge Protection | No | |
| D.12 | Bottom Landing Dimensions (Length x Width) | ≥1.50m x 1.50m | |
| D.13 | Bottom Landing Tactile Warning Strip | No | |



| LEGEND | | |
|---------------|---------------------|-------------------------------|
| ITEM# | ABBREVIATION | MEANING |
| 01 | CY | Cypriot Dialect Sign Language |
| 02 | EN | English Sign Language |
| 03 | GR | Greek Sign Language |
| 04 | TG | Tactile Guidance |
| 05 | INA | Information Not Available |
| 06 | N/A | Not Applicable |
| 07 | OSS | Out of Specifications |
| 08 | r | Radius |
| 09 | (L x W) | Length X Width |
| 10 | V | Vehicle Access |
| 11 | BF | Basement Floor |
| 12 | GF | Ground Floor |
| 13 | 1 st | 1 st Floor |
| 14 | 2 nd | 2 nd Floor |
| 15 | MF | Mezzanine Floor |