



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Flat Landscape/Sandy Beach	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free/Automated	
A.06	Drop Off Point	Not Designated	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not Designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes(More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(Locked)/≥90cm	P.08
A.13	Disabled Elevators	No(More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No(More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No(More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No(More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Gravel	P.10
A.20	Surface Materials – General Beach Area	Sand	P.11
A.21	Surface Materials – Seating Area	Sand/Wood	P.12.1-2
A.22	Surface Materials – Water Fountain Area	N/A (More info in part B)	P.13
A.23	Surface Materials – Bar-B-Que Area	N/A (More info in part B)	P.14
A.24	Surface Materials – Playground Area	N/A (More in part B)	P.15
A.25	Drain Covers Types	No (See Photos)	P.16
A.26	Indoor Light Intensity(LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Recreational Facility	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	P.17
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	
B.04	Inclusive Furnishings	No	P.18
B.05	Inclusive Furnishings Location	N/A	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	N/A	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Difficult Access	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacles Area Access	N/A	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Beach Area Signage	Partial	P.24
B.15	Canteen Counter Height	115cm	P.25
B.16	Public Showers	N/A	P.26
B.17	Public Change Rooms	N/A	P.27
B.18	Inclusive Outdoor Gym	N/A	P.28
B.19	Beach Area Disabled Access	Accessible/ Difficult Access	P.29.1-3
B.20	Kohili Bar Entrance (Door Operation)	Door Handles	P.30
B.21	Kohili Bar Entrance (Door Type/Single Door Width)	Double/Transparent/70cm	
B.22	Kohili Bar Entrance (Door Opening Direction)	Inwards/Right	
B.23	Kohili Bar Entrance (Threshold Height)	N/A	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	General Beach Area	P.06.1-2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 3.35m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	9-20% - 40.00m x 3.35m	
D.08	Inclined Plane Handrails information	One Side	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	90cm & 115cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	OOS	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Bathroom Area	P.06.3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	9-14% - 3.20m x 1.50m	
D.08	Inclined Plane Handrails information	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	OOS	
D.13	Bottom Landing Tactile Warning Strip	No	



(D) ACCESS RAMPS DETAILS – RAMP #03(≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Kohili Entrance	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	OOS	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - 1.00m x 1.40m	
D.08	Inclined Plane Handrails information	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor