

(Closed)

(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Levels	1 - (GF)	P.01
A.02	Receptionist	N/A	
A.03	Qualified Singer / Languages Spoken	N/A	
A.04	Site Access	Pedestrian/ Wheel Chair/ V	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Not Designated	P.02.1-2
A.07	Onsite Disabled Parking Spaces(3.30x5.00m)	Not Designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking(2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-2
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	No	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	N/A	
A.14	Disabled Elevators	No	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	INA (CLOCED)	
A.19	Staircase Disabled Emergency Waiting Point	No	
A.20	Surface Materials – Parking Area	N/A	P.10
A.21	Surface Materials – Entrance	Ceramic Tiles	P.11
A.22	Surface Materials – Narthex (Narthikas)	INA (CLOCED)	P.12
A.23	Surface Materials – Nave	INA (CLOCED)	P.13
A.24	Surface Materials – Iconostasi	INA (CLOCED)	P.14
A.25	Surface Materials – Outdoor Gathering Spaces	Ceramic Tiles	P.15
A.26	Narthex/West Vestibule Information	INA (More info in part B)	
A.27	Narthex/West Entrance (Wheelchair Accessible)	Not Wheelchair Accessible	P.16
A.28	Narthex/West Entrance (Steps)	Yes	
A.29	Narthex/West Door Operation	Door Handles	
A.30	Narthex/West Door Type/ Single Door Width	Double/Opaque/65cm	
A.31	Narthex/West Door Opening Direction	Outwards/Right	
A.32	Narthex/West Door Threshold Height	2cm	
A.33	Wheelchair Accessible Entrance	Yes (More info in part B)	P.17
A.34	Drain Covers Types	No (See Photos)	P.18
A.35	Indoor Light Intensity(LUX)	INA	
A.36	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Chapel	
B.02	North Entrance (Wheelchair Accessible)	Not Wheelchair Accessible	P.19
B.03	North Entrance (Steps)	Yes	
B.04	North Door Operation	Door Handles	
B.05	North Entrance (Door Type/Single Door Width)	Double/Opaque/65cm	
B.06	North Entrance (Door Opening Direction)	Outwards/Right	
B.07	North Entrance (Threshold Height)	2cm	
B.08	South Entrance (Wheelchair Accessible)	Wheelchair Accessible	P.20
B.09	South Entrance (Steps)	No	
B.10	South Door Operation	Door Handles	
B.11	South Entrance (Door Type/Single Door Width)	Double/Opaque/65cm	
B.12	South Entrance (Door Opening Direction)	Outwards/Right	
B.13	South Entrance (Threshold Height)	4cm	
B.14	Church Counter Height	INA (CLOCED)	P.21
B.15	Church Candle Holder Height	INA (CLOCED)	P.22
B.16	Wheelchair Spaces Available	No	P.23
B.17	Wheelchair Spaces (Row Location)	N/A	
B.18	Church Iconostasi Wheelchair Access	INA (CLOCED)	P.24
B.19	Vestibule Dimensions (L x W)	INA (CLOCED)	
B.20	Vestibule Interior Door Operation	INA (CLOCED)	
B.21	Vestibule Interior Door (Type/ Single Door Width)	INA (CLOCED)	
B.22	Vestibule Interior Door Opening Direction	INA (CLOCED)	
B.23	Inclusive Site/Building Furnishings	No	P.25
B.24	South Access Point Width	80cm	P.26



(D) ACCESS RAMPSDETAILS – RAMP #01(≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Hotel Area/Chapel Area	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.15m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	20% - 2.80m x 1.15m	
D.08	Inclined Plane Handrails information	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPSDETAILS – RAMP #02(≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Chapel Area/South Entrance	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	17% - 0.90m x 1.10m	
D.08	Inclined Plane Handrails information	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	



(E) SIGNAGE INFORMATION			
ITEM#	AREA –SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	No (Luminus)	
E.18	Facility’s Outdoor Area – Site/Building Diagram	No	
E.19	Facility’s Outdoor Area – Directional	No	
E.20	Other(Description)	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible