



<b>(A) GENERAL SITE/BUILDING INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
A.01	Number of Floors	1	P.01.1-3
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Wheel Chair/Difficult Access	
A.05	Parking Area Access	N/A	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	No	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(1.80mx1.87m)/ ≥90cm Not Accessible	P.08
A.13	Disabled Elevators	No	P.09
A.14	Tactile Site/Building Guidance	No	
A.15	Braille Writing System Signage/Tactile Diagrams	No	
A.16	Hearing/Speech Impaired Communication Syst.	No	
A.17	Emergency Alerting Systems	Yes(Audible)	
A.18	Staircase Disabled Emergency Waiting Point	No	
A.19	Surface Materials – Parking Area	N/A	P.10
A.20	Surface Materials – Entrance	Tiles	P.11
A.21	Surface Materials – Reception/Lobby	Tiles	P.12
A.22	Surface Materials – Corridors	Concrete	P.13
A.23	Surface Materials – Other Indoor Spaces	Tiles/Concrete	P.14.1-2
A.24	Surface Materials – Outdoor Gathering Spaces	Stone	P.15.1-3
A.25	Main Entry Vestibule	N/A	
A.26	Main Entry Door Operation	Handrails	
A.27	Main Entry Door Type/ Single Door Width	Double/Wood/≥90cm	
A.28	Main Entry Door Opening Direction	Inwards	
A.29	Main Entry Door Threshold Height	0.07cm	
A.30	Interior Doors Width (min/max width)	≥90cm	
A.31	Corridor Width (min/max width)	0.68cm	
A.32	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.33	Drain Covers Types	Yes (See Photos)	P.16
A.34	Indoor Light Intensity(LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	



<b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
B.01	Special Category Type Site/Building	Listed Building	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Theater Wheelchair Spaces Available	N/A	P.18
B.05	Theater Wheelchair Spaces (Row Location)	N/A	
B.06	Theater Stage/Playing Field Disabled Access	N/A	
B.07	Church Iconostasi Access	N/A	
B.08	Vestibule Dimensions (L x W)	N/A	
B.09	Vestibule Interior Door Operation	N/A	
B.10	Vestibule Interior Door Type/ Single Door Width	N/A	
B.11	Vestibule Interior Door Opening Direction	N/A	
B.12	Playground Accessibility	N/A	P.19
B.13	Special Needs Playground Equipment	N/A	P.20
B.14	Inclusive Site/Building Furnishings	N/A	P.21
B.15	Food-Drinks Sale/Retail Sale Counters Heights	N/A	P.22
B.16	Customer Area Space Available (r ≥1.50m) or d	N/A	
B.17	Reception Height	≥1.00m	P.23

<b>(C) ELEVATOR INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
C.01	Elevators for Disabled	1	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door - Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	Yes	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



<b>(D) ACCESS RAMPS DETAILS - RAMP #01 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	WC Entrance	P.06
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	9% - 1.98m x 1.20m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

<b>(D) ACCESS RAMPS DETAILS - RAMP #02 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 <sup>st</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	1 <sup>st</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 <sup>st</sup> Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 <sup>st</sup> Inclined Plane - Width between Handrails	1.00m	
D.11	1 <sup>st</sup> Inclined Plane Edge Protection	Yes	
D.12	1 <sup>st</sup> intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 <sup>st</sup> Landing Handrails information	Both Sides/One Side/No	
D.14	1 <sup>st</sup> Landing Edge Protection	Yes	
D.15	2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 <sup>nd</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 <sup>nd</sup> Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 <sup>nd</sup> Inclined Plane - Width between Handrails	1.00m	
D.19	2 <sup>nd</sup> Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



<b>(D) ACCESS RAMPS DETAILS - RAMP #02 (&lt; 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Wheelchair Entrance	P.06.1-2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	3% - 6.20 m x 3.10m	



<b>(E) SIGNAGE INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – SIGNAGE PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01.3
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.24
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility’s Outdoor Area – Site/Building Diagram	No	
E.19	Facility’s Outdoor Area – Directional	No	
E.20	Other(Description)	No	



<b>(F) HEARING &amp; SPEECH IMPAIRED INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	CY, GR, EN, No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

<b>(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE</b>			
<b>ITEM#</b>	<b>TACTILE PROVISION (FROM – TO)</b>	<b>CHECKLIST</b>	<b>PHO#</b>
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Side to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

<b>(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM &amp; TACTILE DIAGRAMS</b>			
<b>ITEM#</b>	<b>BRAILLE &amp; TACTILE DIAGRAM PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	Door Handle Side	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	