



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Flat Sandy Beach	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Pedestrian	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	2- (3.20X5.00m)	P.03
A.08	Onsite Wheelchair-Accessible VehicleParking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-5
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	2-(Locked)/ ≥90cm	P.08
A.13	Disabled Elevators	No (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Asphalt	P.10
A.20	Surface Materials – General Beach and Bar Area	Sand/Grass/Tiles	P.11.1-2
A.21	Surface Materials – Seating Area	Grass/Tiles	P.12
A.22	Surface Materials – Water Fountain Area	N/A	P.13
A.23	Surface Materials – Bar-B-Que Area	N/A	P.14
A.24	Surface Materials – Playground Area	N/A	P.15
A.25	Drain Covers Types	No	P.16
A.26	Indoor Light Intensity(LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Urban Coastal Park	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Yes/Accessible	P.18
B.05	Inclusive Furnishings Location	Close to Canteen	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	N/A	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Not Accessible	P.20
B.11	Disabled Friendly Trash Receptacles	Partial	P.21
B.12	Recycle Receptacles Area Access	Not Accessible	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Urban Coastal Area Signage	Partial	P.24
B.15	Bar Counter Height	1.05m	P.25
B.16	Public Showers	Not Accessible	P.26
B.17	Public Change Rooms	Not Accessible	P.27



(A) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Beach Area	P.06.1-5
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	17%-3.20m x 1.50m	
D.08	1 st Inclined Plane Handrails information	One Side	
D.09	1 st Inclined PlnHandrails Height (70cm & 90cm)	35cm & 95cm	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.50m	
D.13	1 st Landing Handrails information	One Side	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	15% - 6.50m x 1.00-2.00m	
D.16	2 nd Inclined Plane Handrails information	One Side	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	35cm & 95cm	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.50m	
D.21	Bottom Landing Tactile Warning Strip	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access