



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	2 – (GF, 1 st Accessible)	P.01.1-2
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheel Chair	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	1 - (1.80 x 6.40m)	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-5
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(1.95x1.95m)/ ≥90cm	P.08
A.13	Disabled Elevators	Yes (More info in part C)	P.09.1-2
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	Yes(Audible)	
A.18	Staircase Disabled Emergency Waiting Point	No	
A.19	Surface Materials – Parking Area	Asphalt	P.10
A.20	Surface Materials – Entrance	Concrete Blocks	P.11
A.21	Surface Materials – Reception/Lobby	Industrial Floor	P.12
A.22	Surface Materials – Corridors	Industrial Floor	P.13
A.23	Surface Materials – Other Indoor Spaces	Industrial Floor	P.14
A.24	Surface Materials – Outdoor Gathering Spaces	Concrete Blocks	P.15
A.25	Main Entry Vestibule	No (More info in part B)	
A.26	Main Entry Door Operation	Door Handles	
A.27	Main Entry Door Type/ Single Door Width	Double/Transparent/≥90cm	
A.28	Main Entry Door Opening Direction	Swing	
A.29	Main Entry Door Threshold Height	2cm	
A.30	Interior Doors Width (min/max width)	80cm/≥90cm	
A.31	Corridor Width (min/max width)	1.00m/1.35m	
A.32	Corridor Widening Point (≥1.80x1.80m)	No	
A.33	Drain Covers Types	No (See Photos)	P.16
A.34	Indoor Light Intensity(LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Cultural Centers	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	No	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	No	P.17
B.04	Disabled Seats	Yes	P.18
B.05	Disabled Seats (Row Location)	N/A	
B.06	Theater Stage/Playing Field Disabled Access	No	
B.07	Church Iconostasi Access	No	
B.08	Vestibule Dimensions (L x W)	N/A	
B.09	Vestibule Interior Door Operation	N/A	
B.10	Vestibule Interior Door Type	N/A	
B.11	Vestibule Interior Door Opening Direction	N/A	
B.12	Playground Accessibility	No	P.19
B.13	Special Needs Playground Equipment	No	P.20
B.14	Inclusive Site/Building Furnishings	No	P.21
B.15	Other(Description)	No	P.22

(C) ELEVATOR INFORMATION

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1	P.09.1-2
C.02	Floor Announcement System	No	
C.03	Control Panel with Tactile Numbers & Braille	No	
C.04	Warning Floor Strip	No	
C.05	Waiting Area (Door – Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	Low	P.09.1-2
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	Yes	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	N/A	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	No(Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Outdoor/ Entrance	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - 0.60m x 1.05m	
D.08	Inclined Plane Handrails information	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	OOS	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Indoor/Lecture Hall	P.06.2-3
D.02	Rain Protection System	Yes	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	1.35m x 1.55m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	12% - 3.50m x 1.35m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	Inclined Plane - Width between Handrails	1.05m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	3.15m x 1.35m	
D.13	Bottom Landing Tactile Warning Strip	No	



(D) ACCESS RAMPS DETAILS – RAMP #03 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Indoor/Bathroom	P.06.4-5
D.02	Rain Protection System	Yes	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.35m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	9%-4.15m x 1.35m	
D.08	1 st Inclined Plane Handrails information	Both Sides	
D.09	1 st Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.10m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.35m x 1.35m	
D.13	1 st Landing Handrails information	Both Sides	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	9% - 3.10m x 1.35m	
D.16	2 nd Inclined Plane Handrails information	Both Sides	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.10m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.35m	
D.21	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #03 (<5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.07	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	



(E) SIGNAGE INFORMATION			
ITEM#	AREA –SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01
E.03	Parking – Disabled Parking Space Symbol	Yes	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	No	P.23
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	CY, GR, EN, No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Side to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	Door Handle Side	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OOS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor