



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Flat Landscape	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Pedestrian/ Wheel Chair/ V	
A.05	Parking Area Access	No Parking Available	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	Yes (2.25x1.95m)/ ≥90cm	P.08
A.13	Disabled Elevators	No (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	N/A	P.10
A.20	Surface Materials – General Park Area	Earth/Concrete/Gravel/Stone	P.11.1-8
A.21	Surface Materials – Seating Area	Rubber/Stone/Concrete/Wood	P.12
A.22	Surface Materials – Water Fountain Area	N/A	P.13
A.23	Surface Materials – Bar-B-Que Area	N/A	P.14
A.24	Surface Materials – Playground Area	Rubber	P.15.1-3
A.25	Drain Covers Types	No (See Photos)	P.16
A.26	Indoor Light Intensity(LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Urban Park	
B.02	Service Counter Height/Knee Space	N/A	
B.03	Service Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Accessible	P.18
B.05	Inclusive Furnishings Location	Playground/Canteen	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	Accessible	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Difficult Access	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacles Area Access	Not Available	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Park Area Signage	Partial	P.24
B.15	Canteen Counter Height	1.20m	P.25
B.16	West - North Access Point Width	80cm	P.26
B.17	West - South Access Point Width	80cm	P.27
B.18	East - South Access Point Width	≥90cm	P.28
B.19	East - North Access Point Width	Not Accessible	P.29
B.20	North Access Point Width	Not Accessible	P.30

**(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	West – North Access Point	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	13% - 2.40m x1.50m	
D.08	Inclined Plane Handrails	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	OOS (Street)	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Playground Area	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	7% - 8.00m x1.20m	
D.08	Inclined Plane Handrails	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	75cm & 95cm	
D.10	Inclined Plane - Width between Handrails	1.15m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #03 (≥5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Playground Area	P.06.3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	6% - 7.70m x1.20m	
D.08	Inclined Plane Handrails	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	77cm & 97cm	
D.10	Inclined Plane - Width between Handrails	1.17m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #04 (≥5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Bathroom & Canteen Area	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	6% - 7.00m x1.50m	
D.08	Inclined Plane Handrails	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	77cm & 97cm	
D.10	Inclined Plane - Width between Handrails	1.43m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OOS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access