



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	2 - (GF, Accessible)	P.01.1-2
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Pedestrian/ Vehicle	
A.05	Parking Area Access	Automated	
A.06	Drop Off Point	Yes(No Designated Area)	P.02
A.07	Onsite Disabled Parking Spaces(3.30x5.00m)	18- (3.30X5.00m)	P.03.1-2
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking(2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes(More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ IntDimensions)	7 / 2.00m x 200m	P.08.1-4
A.13	Disabled Bathrooms (Door width/Threshold Height)	80-86cm / 0cm	
A.14	Disabled Elevators	Yes (More info in part C)	P.09
A.15	Tactile Site/Building Guidance	Yes (More info in part G)	
A.16	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.17	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.18	Emergency Alerting Systems	Yes (Audible & Visual)	
A.19	Staircase Disabled Emergency Waiting Point	No	
A.20	Surface Materials – Parking Area	Asphalt	P.10
A.21	Surface Materials – Entrance	Concrete	P.11
A.22	Surface Materials – Reception/Lobby	Ceramic Tiles	P.12
A.23	Surface Materials – Corridors	Ceramic Tiles	P.13.1-2
A.24	Surface Materials – Other Indoor Spaces	Ceramic Tiles/Industrial F.	P.14.1-3
A.25	Surface Materials – Outdoor Gathering Spaces	Asphalt/Concrete	P.15
A.26	Main Entry Vestibule	No (More info in part B)	
A.27	Main Entry Door Operation	Door Handles	P.16
A.28	Main Entry Door Type/ Single Door Width	Double/Transparent/80cm	
A.29	Main Entry Door Opening Direction	Swing	
A.30	Main Entry Door Threshold Height	N/A	
A.31	Wheelchair Accessible Entrance	N/A (More info in part B)	P.17
A.32	Interior Doors (single door min/max width)	80cm/85cm	
A.33	Corridor Width (min/max width)	1.10m/≥1.50m	
A.34	Corridor Widening Point (≥1.80x1.80m)	No	
A.35	Drain Covers Types	Yes (See Photos)	P.18.1-2
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Public Buildings	
B.02	Wheelchair Accessible Entrance (Door Operation)	N/A	P.17
B.03	WCA Entrance(Door Type/Single Door Width)	N/A	
B.04	WCA Entrance(Door Opening Direction)	N/A	
B.05	WCA Entrance(Threshold Height)	N/A	
B.06	Service Counter Height/Knee Space(70cm/60cm)	105cm/30cm	P.19
B.07	Service Counter Area (r ≥1.50m) or Dimensions	≥1.50m	
B.08	Wheelchair Spaces Available	N/A	P.20
B.09	Wheelchair Spaces (Row Location)	N/A	
B.10	Theater Stage/Playing Field Disabled Access	N/A	
B.11	Church Iconostasi Access	N/A	
B.12	Vestibule Dimensions (L x W)	N/A	
B.13	Vestibule Interior Door Operation	N/A	
B.14	Vestibule Interior Door (Type/ Single Door Width)	N/A	
B.15	Vestibule Interior Door Opening Direction	N/A	
B.16	Playground Accessibility	N/A	P.21
B.17	Special Needs Playground Equipment	No	P.22
B.18	Inclusive Site/Building Furnishings	No	P.23
B.19	#01 Passenger Hall-Customs-Exit Area (WCA)	Wheelchair Accessible	P.24.1-2
B.20	#02 Passenger Hall-Baggage Claim (WCA)	Wheelchair Accessible	P.25.1-5
B.21	#03 Passenger Hall-Arrivals (WCA)	Wheelchair Accessible	P.26.1-5
B.22	Arrivals Area Doors (Type/Single Door Width)	Double/Transparent/80cm	P.27.1-2
B.23	Passport Control Counter Height/Knee Space	102cm/0cm	P.28.1-2
B.24	Passport Control Counter Area (r ≥1.50m)	≥1.50m	
B.25	#05 Passenger Hall-Departures Check In Area	Wheelchair Accessible	P.29.1-3
B.26	Service Counter Height/Knee Space(70cm/60cm)	110cm/0cm	P.30
B.27	Service Counter Area (r ≥1.50m) or Dimensions	≥1.50m	
B.28	#06 Passenger Hall-Departures	Wheelchair Accessible	P.31.1-4
B.29	Departures Area Doors (Type/Single Door Width)	Double/Transparent/80cm	P.32
B.30	Passport Control Counter Height/Knee Space	102cm/0cm	P.33
B.31	Passport Control Counter Area (r ≥1.50m)	≥1.50m	
B.32	#07 Passenger Hall-Duty Free Shops-Café	Wheelchair Accessible	P.34.1-2
B.33	Medical Room	Wheelchair Accessible	
B.34	Service for Disabled Persons	Wheelchair	P.35

**(C) ELEVATOR INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1(Locked)	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door – Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	Yes	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	

(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	#05-Outdoor/ Departures	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	5% - 20.0m x 15.00m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	75cm & 105cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	#06-Outdoor/ Departures	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	7% - 20.0m x 12.00m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	75cm & 105cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #03 (≥5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	#03-Outdoor/ Arrivals	P.06.3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	6% - 20.0m x 11.20m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	75cm & 105cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #04 (≥5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	#01-Outdoor/Arrivals	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	5% - ≥10.00m x ≥7.00m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	75cm & 105cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x ≥1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(E) SIGNAGE INFORMATION

ITEM#	AREA –SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01
E.03	Parking – Disabled Parking Space Symbol	Yes	
E.04	Parking – International Accessibility Symbol	Yes	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	Yes	
E.11	Entrance/Reception – Bathroom Location	Yes	
E.12	Entrance/Reception – General Information	Yes	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.25
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	Yes	
E.16	Inside Facility – Bathroom Location	Yes	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	Yes	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	CY, GR, EN, No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	Yes	
G.02	Public Sidewalk to Entrance	Partial	
G.03	Parking Area to Entrance	Partial	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	Door Handle Side	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible