



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Flat & Sloped Terrain	P.01.1-2
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	No Parking Available	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(2.15x2.90m)/ ≥90cm	P.08
A.13	Disabled Elevators	No (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	N/A	P.10
A.20	Surface Materials – Entrance	Asphalt/Concrete	P.11
A.21	Surface Materials – Reception/Lobby	Concrete	P.12
A.22	Surface Materials – Corridors	Asphalt/Earth	P.13
A.23	Surface Materials – Other Indoor Spaces	N/A	P.14
A.24	Surface Materials – Outdoor Gathering Spaces	Earth	P.15
A.25	Main Entry Vestibule	No (More info in part B)	
A.26	Main Entry Door Operation	N/A	
A.27	Main Entry Door Type	N/A	
A.28	Main Entry Door Opening Direction	N/A	
A.29	Main Entry Door Threshold Height	N/A	
A.30	Interior Doors Width (min/max width)	N/A	
A.31	Corridor Width (min/max width)	1.00m/3.00m	
A.32	Corridor Widening Point (≥1.80x1.80m)	No	
A.33	Drain Covers Types	No	P.16
A.34	Indoor Light Intensity(LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Archaeological Site	
B.02	Archaeological Site Accessibility	Partial	P.24.1-4
B.03	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	
B.04	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.05	Disabled Seats	N/A	P.18
B.06	Disabled Seats (Row Location)	N/A	
B.07	Theater Stage/Playing Field Disabled Access	N/A	
B.08	Church Iconostasi Access	N/A	
B.09	Vestibule Dimensions (L x W)	N/A	
B.10	Vestibule Interior Door Operation	N/A	
B.11	Vestibule Interior Door Type	N/A	
B.12	Vestibule Interior Door Opening Direction	N/A	
B.13	Playground Accessibility	No	P.19
B.14	Special Needs Playground Equipment	No	P.20
B.15	Inclusive Site/Building Furnishings	N/A	P.21
B.16	Other(Description)	No	P.22

(C) ELEVATOR INFORMATION

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door – Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	Yes	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Bathroom Area	P.06
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	7%-3.00m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides	
D.09	1 st Inclined PlnHandrails Height (70cm & 90cm)	70cm & 95cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.20m x 1.10m	
D.13	1 st Landing Handrails information	Both Sides	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	9% - 2.40m x 1.15m	
D.16	2 nd Inclined Plane Handrails information	Both Sides	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 95cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.21	Bottom Landing Tactile Warning Strip	No	

**(D) SIGNAGE INFORMATION**

ITEM#	AREA –SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	Yes	
E.12	Entrance/Reception – General Information	Yes	
E.13	Inside Facility – Exhibition Area Labels	Insufficient	P.23
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	No (Luminus)	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	

LEGEND



ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible