



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Urban Park	P.01.1-5
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheelchair/TG	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	Not designated	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	1-3.00m x 5.10m	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(2.35x2.10m)/ ≥90cm	P.08.1-4
A.13	Disabled Elevators	N/A	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Asphalt	P.10
A.20	Surface Materials – General Picnic/Park Area	Earth/Brick paving	P.11.1-7
A.21	Surface Materials – Seating Area	Earth/Brick paving	P.12.1-3
A.22	Surface Materials – Water Fountain Area	No	P.13
A.23	Surface Materials – Bar-B-Que Area	N/A	P.14
A.24	Surface Materials – Playground Area	Rubber/ artificial grass carpet (More in part B)	P.15.1-3
A.25	Drain Covers Types	No	P.16
A.26	Indoor Light Intensity (LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Urban Park	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	P.17
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	No	P.18
B.05	Inclusive Furnishings Location	N/A	
B.06	Disabled Friendly Water Fountains	N/A	P.13
B.07	Disabled Friendly Bar-B-Que	N/A	P.14
B.08	Playground Area Disabled Access	Partially Accessible	P.15.1-3
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Partially Accessible	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21.1-2
B.12	Recycle Receptacles Area Access	Accessible	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Picnic Area Signage	No	P.24
B.15	Canteen Counter Height	Steps	P.25
B.16.1	Other: TG around the park doesn't lead to the entrances and into the park	Yes	P.26.1
B.16.2	Main West Entry paving	Damaged/ not leveled	P.26.2-3



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	West Entrance	P.06.1-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	13%- 11.00m x 1.50m	
D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm&90cm)	70cm & 90cm/ 90cm	
D.10	Inclined Plane - Width between Handrails	1.40m	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.10m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	North Entrance	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	19%- 2.00m x 1.60m	
D.08	1 st Inclined Plane Handrails information	No	
D.09	1 st Inclined Plane Handrails Height (70cm&90cm)	N/A	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	One Side	
D.12	1 st intermediate Level Landing (Length x Width)	1.20m x 1.60m	
D.13	1 st Landing Handrails information	No	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	7% - 11.00m x 1.60m	
D.16	2 nd Inclined Plane Handrails information	N/A	
D.17	2 nd Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	East Entrance – from road	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	9%- 0.60m x 4.00m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm&90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.10m	
D.13	Bottom Landing Tactile Warning Strip	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor