



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	2	P.01.1-2
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheel Chair	
A.05	Parking Area Access	Security	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	2/ 3.50m X 5.30m	P.03.1-2
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No (4.80m x 6.00m)	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	1 per gender at back stage / 1.80m x 1.50m 2 per gender for audience/ 1.80 x 1.95m (GF, 1 st)	P.08.1-5 P.08.6-8
A.13	Disabled Bathrooms (Door width/Threshold Height)	90cm / 0cm	
A.14	Disabled Elevators	3 (More info in Part C)	P.09.1-6
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	Yes (Audible)	
A.19	Staircase Disabled Emergency Waiting Point	Yes (More info in part B.19)	
A.20	Surface Materials – Parking Area	Concrete	P.10
A.21	Surface Materials – Entrance	Marble	P.11
A.22	Surface Materials – Reception	Marble	P.12
A.23	Surface Materials – Corridors	Vinyl (backstage)/ Marble	P.13.1-2
A.24	Surface Materials – Other Indoor Spaces	Vinyl/ Marble	P.14.1-5
A.25	Surface Materials – Outdoor Gathering Spaces	Marble/ Concrete Tiles	P.15.1-2
A.26	Main Entry Vestibule	Yes	
A.27	Main Entry Door Operation	Push-Pull	P.16.1-2
A.28	Main Entry Door Type/ Single Door Width	4 sets of Double / Transparent/ 93cm	
A.29	Main Entry Door Opening Direction	Outwards/ Left & Right	
A.30	Main Entry Door Threshold Height	No	
A.31	Wheelchair Accessible Entrance	Yes (More info in part B)	P.16.1-2
A.32	Interior Doors (single door min/max width)	90cm/ 1.00m	
A.33	Corridor Width (min/max width)	1.10m/ ≥1.80m	
A.34	Corridor Widening Point (≥1.80x1.80m)	No	
A.35	Drain Covers Types	No	P.18
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Theatre	
B.02	Wheelchair Accessible Entrance (Door Operation)	Push-Pull	P.16.1-2
B.03	WCA Entrance (Door Type/Single Door Width)	(More info in Part A.27 – A.30)	P.16.1-2
B.04	WCA Entrance (Door Opening Direction)	(More info in Part A.27 – A.30)	P.16.1-2
B.05	WCA Entrance (Threshold Height)	(More info in Part A.27 – A.30)	P.16.1-2
B.06	Service Counter Height/Knee Space (70cm/60cm)	1.00m/0cm	P.19
B.07	Service Counter Area ($r \geq 1.50m$) or Dimensions	$r \geq 1.50m$	
B.08	Wheelchair Spaces Available	18 (10 at GF, 8 at balcony)	P.20.1-7
B.09	Wheelchair Spaces (Row Location)	R01	
B.10	Theater Stage/Playing Field Disabled Access	No	
B.11	Church Iconostasi Access	N/A	
B.12	Vestibule Dimensions (L x W)	2.00m x 4.00m	
B.13	Vestibule Interior Door Operation	Push-Pull	
B.14	Vestibule Interior Door (Type/ Single Door Width)	2 sets of Double / Transparent/ 93cm	
B.15	Vestibule Interior Door Opening Direction	Outwards/ Left & Right	
B.16	Playground Accessibility	N/A	P.21
B.17	Special Needs Playground Equipment	N/A	P.22
B.18	Inclusive Site/Building Furnishings	N/A	P.23
B.19.1	Other: Staircase Disables Emergency waiting Point & Evacuation equipment (at back stage service area & foyer)	Yes	P.24.1-2
B.19.2	Other: Staircase (Handrails)	Yes (90cm/ 115cm)	P.24.3

(C) ELEVATOR INFORMATION #1

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1 (service Lift #1)	P.09.1-3
C.02	Floor Announcement System	No	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	No	
C.05	Waiting Area (Door – Wall Distance $\geq 150cm$)	Yes	
C.06	Door – Frame Colour Contrast	Medium	P.09.1
C.07	Door Width $\geq 90cm$	$\geq 90cm$	
C.08	Elevator Cabin Dimensions ($\geq 110 \times 140cm$)	0.95m x 1.62m	
C.09	Elevator Cabin Dimensions ($\geq 110 \times 220cm$)	No	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	No	
C.14	Cabin Anti-Slip, non-Reflective Floor	No	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	

**(C) ELEVATOR INFORMATION #2**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1 (service Lift #2)	P.09.3-4
C.02	Floor Announcement System	No	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	No	
C.05	Waiting Area (Door – Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Colour Contrast	Medium	P.09.3
C.07	Door Width ≥90cm	≥90cm	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	1.50m x 1.55m	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	No	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	No	
C.14	Cabin Anti-Slip, non-Reflective Floor	No	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	

(C) ELEVATOR INFORMATION #3

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1 (foyer)	P.09.5-6
C.02	Floor Announcement System	No	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	No	
C.05	Waiting Area (Door – Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Colour Contrast	Medium	P.09.5
C.07	Door Width ≥90cm	≥90cm	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	1.40m x 1.60m	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	No	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	No	
C.14	Cabin Anti-Slip, non-Reflective Floor	No	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance (service area)/ Outdoor	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	10% - 0.50m x 1.00m	
D.08	Inclined Plane Handrails information	N/A	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	N/A	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/ Outdoor	P.06.3-5
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 st Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 st Landing Handrails information	Both Sides/One Side/No	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	2- Theatre Entrance/ Outdoor	P.06.2-4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4% - 5.95m x 1.90m-3.95m	

(D) ACCESS RAMPS DETAILS – RAMP #04 (< 5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	2- to stage & seats/ Indoor	P.06.4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	5% - 4.50m x 1.50m	

(D) ACCESS RAMPS DETAILS – RAMP #05 (< 5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	2- to WCA seats/ Indoor	
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	5% - 2.50m x 1.80m	



(E) SIGNAGE INFORMATION			
ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01.1-3
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	Yes	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.25
E.14	Inside Facility – Site/Building Diagram	Yes (backstage only)	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	N/A	
H.09	Outdoor Areas – General Information in Braille	N/A	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

POSSIBLE ANSWERS		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial