



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Urban Features	Street Refurbishment	P.01.1-18
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/ Wheelchair/ TG	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	N/A	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	2/ 3.10mx6.30m (Zinas Kanther) 2/ 3.10mx6.30m (Stasikratous)	P.05.1-2 P.05.3-4
A.10	Access Ramps	No (More info in part D)	P.06
A.11	Lifting Platforms	N/A	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	No	P.08
A.13	Disabled Elevators	N/A	
A.14	Tactile Site/Building Guidance	Yes (More info in part G)	P.09.1-14
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	N/A	
A.17	Emergency Alerting Systems	N/A	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area /on street	Cobblestone/ Tiles	P.10
A.20	Surface Materials – General Paved Area	Cobblestone/ Tiles	P.11.1-2
A.21	Surface Materials – Seating Area	Cobblestone & Tiles	P.12.1-2
A.22	Surface Materials – Water Fountain Area	Yes (More info in Part B)	P.13.1-4
A.23	Surface Materials – Bar-B-Que Area	N/A	P.14
A.24	Surface Materials – Playground Area	N/A	P.15
A.25	Drain Covers Types	Yes	P.16
A.26	Indoor Light Intensity(LUX)	N/A	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Urban Refurbishment	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	P.17
B.03	Ticket Counter Area (r ≥ 1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	No	P.18
B.05	Inclusive Furnishings Location	N/A	
B.06	Disabled Friendly Water Fountains	Partially (not WCA)	P.13.3
B.07	Disabled Friendly Bar-B-Que	N/A	P.14
B.08	Playground Area Disabled Access	N/A	P.15
B.09	Special Needs Playground Equipment	N/A	P.19
B.10	Trash Receptacles Area Access	Accessible	P.20
B.11	Disabled Friendly Trash Receptacles	Yes	P.21
B.12	Recycle Receptacles Area Access	N/A	P.22
B.13	Disabled Friendly Recycled Receptacles	N/A	P.23
B.14	Urban Area Signage	Yes (Street Signage)	P.24
B.15.1	Other: The regeneration applies to the following streets: Makariou, Stasikratous, Zinas Kanther Mnasiadou, Theofanous Theodotou & Evagorou.	Yes	
B.15.2	Additional On-Street Disabled Parking available on adjacent streets: Foti Pitta (1), Promitheos (1), Prevezis (1), Stasandrou (1), Gregorou Xenopoulou (1), Ayias Elenis (1)		



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	General Picnic Area	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	10% - 18.0m x 2.00m	
D.08	Inclined Plane Handrails	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	5%-10.0m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 st Inclined PlnHandrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 st Landing Handrails information	Both Sides/One Side/No	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



(D) ACCESS RAMPS DETAILS – RAMP #04 (<5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Along sidewalks & squares	P.06.1-4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Bottom Landing Dimensions (Length x Width)	N/A	
D.06	Inclined Plane (Slope-Length x Width)	3% -5% - Varies	

**(E) SIGNAGE INFORMATION**

ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	N/A	
E.02	Site/Building – Site/Building Name	N/A	P.01
E.03	Parking – Disabled Parking Space Symbol	N/A	
E.04	Parking – International Accessibility Symbol	N/A	
E.05	Parking – Building Access Ramp Location	N/A	
E.06	Parking – Site Diagram	N/A	
E.07	Parking – Directional	N/A	
E.08	Parking – General Information	N/A	
E.09	Entrance/Reception – Site/Building Diagram	N/A	
E.10	Entrance/Reception – Directional	N/A	
E.11	Entrance/Reception – Bathroom Location	N/A	
E.12	Entrance/Reception – General Information	N/A	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.25
E.14	Inside Facility – Site/Building Diagram	N/A	
E.15	Inside Facility – Directional	N/A	
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	N/A	
E.18	Facility's Outdoor Area – Site/Building Diagram	N/A	
E.19	Facility's Outdoor Area – Directional	N/A	
E.20	Other: Street name Signage	Yes	

(F) HEARING & SPEECH IMPAIRED INFORMATION

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

**(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE**

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	N/A	
G.03	Parking Area to Public Building Entrance	No	
G.04	Reception to Bathrooms	N/A	
G.05	Reception to other Interior Areas	N/A	
G.06	Interior Areas to Emergency Exit	N/A	
G.07	Interior Areas to Outdoor Spaces	N/A	
G.08	Other: TG is continuous but interrupted by various objects along the path		P.09. 1-14

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	N/A	
H.02	Parking Area – General information in Braille	N/A	
H.03	Entrance/Reception – Tactile Site Diagram	N/A	
H.04	Entrance/Reception – Tactile Building Diagram	N/A	
H.05	Entrance/Recep. – General information in Braille	N/A	
H.06	Inside Facility – Room Info & Number in Braille	N/A	
H.07	Room Info & Number Location in Braille	N/A	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor