



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Plateau & Sloped Areas	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Not Designated	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not Designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	Not Designated	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-2
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(1.70x2.00m)/ 88cm	P.08.1-2
A.13	Disabled Elevators	No (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	N/A	P.10
A.20	Surface Materials – General Picnic Area	Earth	P.11.1-2
A.21	Surface Materials – Seating Area	Earth	P.12
A.22	Surface Materials – Water Fountain Area	Concrete	P.13.1-2
A.23	Surface Materials – Bar-B-Que Area	Concrete	P.14
A.24	Surface Materials – Playground Area	Earth	P.15
A.25	Drain Covers Types	No	P.16
A.26	Indoor Light Intensity(LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Natural Site	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Yes/Difficult Access	P.18
B.05	Inclusive Furnishings Location	Close to Entrance	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	Not Accessible	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Difficult Access	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacle Area Access	Not Available	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Picnic Area Signage	Partial	P.24
B.15	Canteen Counter Height	N/A	P.25



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Picnic Area	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	OOS	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	20% - 4.00m x 1.50m	
D.08	Inclined Plane Handrails	No Handrails	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	OOS	
D.13	Bottom Landing Tactile Warning Strip	N/A	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Bathroom Area	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	20% - 4.00m x 1.50m	
D.08	Inclined Plane Handrails	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	OOS	
D.13	Bottom Landing Tactile Warning Strip	N/A	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible