



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	Outdoor Football Fields	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	N/A	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	Not designated	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	N/A	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	No	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	N/A	
A.14	Disabled Elevators	N/A	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	N/A	
A.19	Staircase Disabled Emergency Waiting Point	N/A	
A.20	Surface Materials – Parking Area	N/A	P.10
A.21	Surface Materials – Entrance	Concrete/ Earth	P.11
A.22	Surface Materials – Reception	N/A	P.12
A.23	Surface Materials – Corridors	N/A	P.13
A.24	Surface Materials – Other Indoor Spaces	N/A	P.14
A.25	Surface Materials – Outdoor Gathering Spaces	N/A	P.15
A.26	Main Entry Vestibule	No	
A.27	Main Entry Door Operation	Push-Pull	P.16
A.28	Main Entry Door Type/ Single Door Width	Double / transparent/1.95m	
A.29	Main Entry Door Opening Direction	Inwards & Outwards/ Left & Right	
A.30	Main Entry Door Threshold Height	Ramps	
A.31	Wheelchair Accessible Entrance	No	P.17
A.32	Interior Doors (single door min/max width)	N/A	
A.33	Corridor Width (min/max width)	N/A	
A.34	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.35	Drain Covers Types	N/A	P.18
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Football training fields	
B.02	Wheelchair Accessible Entrance (Door Operation)	(More info in Part A.27-A.30)	P.16
B.03	WCA Entrance (Door Type/Single Door Width)	(More info in Part A.27-A.30)	P.16
B.04	WCA Entrance (Door Opening Direction)	(More info in Part A.27-A.30)	P.16
B.05	WCA Entrance (Threshold Height)	N/A	P.16
B.06	Service Counter Height/Knee Space (70cm/60cm)	N/A	P.19
B.07	Service Counter Area (r ≥1.50m) or Dimensions	N/A	
B.08	Wheelchair Spaces Available	N/A	P.20
B.09	Wheelchair Spaces (Row Location)	N/A	
B.10	Theater Stage/Playing Field Disabled Access	No	
B.11	Church Iconostasi Access	N/A	
B.12	Vestibule Dimensions (L x W)	N/A	
B.13	Vestibule Interior Door Operation	N/A	
B.14	Vestibule Interior Door (Type/ Single Door Width)	N/A	
B.15	Vestibule Interior Door Opening Direction	N/A	
B.16	Playground Accessibility	N/A	P.21
B.17	Special Needs Playground Equipment	N/A	P.22
B.18	Inclusive Site/Building Furnishings	No	P.23
B.19	Other: (Description)	Yes	

(C) ELEVATOR INFORMATION

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1	P.09.1-4
C.02	Floor Announcement System	No	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	No	
C.05	Waiting Area (Door - Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Colour Contrast	Low	P.09.1
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	Yes (1.20m x 1.40m)	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance to Field B1/ Outdoor	P.06.1-2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - 4.30m x 9.10m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance to Field B2/ Outdoor	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	12% - 4.30m x 9.10m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	



(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	

**(E) SIGNAGE INFORMATION**

ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	N/A	
E.05	Parking – Building Access Ramp Location	N/A	
E.06	Parking – Site Diagram	N/A	
E.07	Parking – Directional	N/A	
E.08	Parking – General Information	N/A	
E.09	Entrance/Reception – Site/Building Diagram	N/A	
E.10	Entrance/Reception – Directional	N/A	P.25
E.11	Entrance/Reception – Bathroom Location	N/A	
E.12	Entrance/Reception – General Information	N/A	
E.13	Inside Facility – Exhibition Area Labels	N/A	
E.14	Inside Facility – Site/Building Diagram	N/A	
E.15	Inside Facility – Directional	N/A	P.26
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	N/A	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	N/A	
F.02	Sign Languages Spoken	N/A	
F.03	Reception Design Specific Space	N/A	
F.04	Visual Emergency Alerting Systems	N/A	
F.05	Augmenting Systems – ex. Induction Loop	N/A	
F.06	Augmenting Systems –ex. Fm	N/A	
F.07	Transforming Systems – ex. Captioned Phone	N/A	
F.08	Transparent Masks for Covid-19	N/A	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	N/A	
G.02	Public Sidewalk to Entrance	N/A	
G.03	Parking Area to Entrance	N/A	
G.04	Reception to Bathrooms	N/A	
G.05	Reception to other Interior Areas	N/A	
G.06	Interior Areas to Emergency Exit	N/A	
G.07	Interior Areas to Outdoor Spaces	N/A	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	N/A	
H.02	Parking Area – General information in Braille	N/A	
H.03	Entrance/Reception – Tactile Site Diagram	N/A	
H.04	Entrance/Reception – Tactile Building Diagram	N/A	
H.05	Entrance/Recep. – General information in Braille	N/A	
H.06	Inside Facility – Room Info & Number in Braille	N/A	
H.07	Room Info & Number Location in Braille	N/A	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

POSSIBLE ANSWERS		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial