



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Levels	1	P.01.1-3
A.02	Receptionist	N/A	
A.03	Qualified Singer / Languages Spoken	N/A	
A.04	Site Access	WC/ Vehicle	
A.05	Parking Area Access	No	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	No	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	N/A	
A.14	Disabled Elevators	N/A	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	No	
A.19	Staircase Disabled Emergency Waiting Point	N/A	
A.20	Surface Materials – Parking Area	N/A	P.10
A.21	Surface Materials – Entrance	Tiles	P.11
A.22	Surface Materials – Narthex (Narthikas)	Tiles	P.12
A.23	Surface Materials – Nave	Tiles	P.13
A.24	Surface Materials – Iconostasi	Carpet	P.14.1-2
A.25	Surface Materials – Outdoor Gathering Spaces	Stone Tiles	P.15
A.26	Narthex/West Vestibule Information	N/A	
A.27	West Door Operation	Push/Pull	P.16.1-3
A.28	West Door Type/ Single Door Width	Double/Outer: semi Transparent/ 55cm / Inner: Opaque/ 70cm	
A.29	West Door Opening Direction	Outwards & Inwards/ Left & Right	
A.30	West Door Threshold Height	0cm	
A.31	Wheelchair Accessible Entrance	Yes (More info in part B)	P.16.1-3
A.32	Drain Covers Types	Yes	P.18
A.33	Indoor Light Intensity(LUX)	INA	
A.34	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Church/Listed/Arch. Mo	
B.02	North Entrance (Wheelchair Accessible)	No	P.19.1-2
B.03	North Entrance (Steps)	No	
B.04	North Entrance (Door Type/Single Door Width)	Double/Outer: semi Transparent/ 55cm / Inner: Opaque/ 70cm	
B.05	North Entrance (Door Opening Direction)	Outwards & Inwards/ Left & Right	
B.06	North Entrance (Threshold Height)	≤10mm/3cm	
B.07	South Entrance (Wheelchair Accessible)	No	P.20.1-2
B.08	South Entrance (Steps)	No	
B.09	South Entrance (Door Type/Single Door Width)	Double/Outer: semi Transparent/ 55cm / Inner: Opaque/ 70cm	
B.10	South Entrance (Door Opening Direction)	Outwards & Inwards/ Left & Right	
B.11	South Entrance (Threshold Height)	≤10mm/3cm	
B.12	Church Counter Height (100cm)	123cm	P.21
B.13	Church Candle Holder Height (100cm)	90cm	P.22
B.14	Wheelchair Spaces Available	Yes	P.23
B.15	Wheelchair Spaces (Row Location)	N/A	
B.16	Church Iconostasi Wheelchair Access	Yes (movable ramp available)	P.24
B.17	Vestibule Dimensions (L x W)	N/A	
B.18	Vestibule Interior Door Operation	N/A	
B.19	Vestibule Interior Door(Type/ Single Door Width)	N/A	
B.20	Vestibule Interior Door Opening Direction	N/A	
B.21	Inclusive Site/Building Furnishings	No	P.25



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/ courtyard/ Outdoor	P.06.1-2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	8% - 5.60m x 4.70m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 st Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 st Landing Handrails information	Both Sides/One Side/No	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	

(E) SIGNAGE INFORMATION

ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	
E.03	Parking – Disabled Parking Space Symbol	N/A	
E.04	Parking – International Accessibility Symbol	N/A	
E.05	Parking – Building Access Ramp Location	N/A	
E.06	Parking – Site Diagram	N/A	
E.07	Parking – Directional	N/A	
E.08	Parking – General Information	N/A	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	No	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

POSSIBLE ANSWERS		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial