



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	1	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access (only from Back-East side)	Vehicle/Wheel Chair	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	N/A	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	No	P.08
A.13	Disabled Elevators	No	P.09
A.14	Tactile Site/Building Guidance	No	
A.15	Braille Writing System Signage/Tactile Diagrams	No	
A.16	Hearing/Speech Impaired Communication Syst.	No	
A.17	Emergency Alerting Systems	No	
A.18	Staircase Disabled Emergency Waiting Point	No	
A.19	Surface Materials – Parking Area	Concrete	P.10
A.20	Surface Materials – Entrance	Tiles	P.11.1-2
A.21	Surface Materials – Reception/Lobby	Terrazzo tiles	P.12
A.22	Surface Materials – Corridors	Terrazzo tiles	P.13
A.23	Surface Materials – Other Indoor Spaces	Terrazzo tiles	P.14
A.24	Surface Materials – Outdoor Gathering Spaces	Concrete/ Stone	P.15.1-5
A.25	Main Entry Vestibule	No	
A.26	Main Entry Door Operation	Push/Pull	
A.27	Main Entry Door Type /width	2 sets Double/ outer: ½ TRN/ inner: opaque/ 1.60m(2x0.80m)	
A.28	Main Entry Door Opening Direction	Outwards + Inwards	
A.29	Main Entry Door Threshold Height	3cm	
A.30	Interior Doors Width (min/max width)	N/A	
A.31	Corridor Width (min/max width)	1.00m - 1.20m	
A.32	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.33	Drain Covers Types	Yes	P.16
A.34	Indoor Light Intensity (LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Building	Church	
B.02	Counter Height	≥1.00m	
B.03	Counter Area	r ≥1.50m	P.17
B.04	Disabled Seats	No	P.18
B.05	Disabled Seats (Row Location)	No	
B.06	Theater Stage/Playing Field Disabled Access	N/A	
B.07	Church Iconostasi Access	No	
B.08	Vestibule Dimensions (L x W)	N/A	
B.09	Vestibule Interior Door Operation	N/A	
B.10	Vestibule Interior Door Type	N/A	
B.11	Vestibule Interior Door Opening Direction	N/A	
B.12	Playground Accessibility	N/A	P.19
B.13	Special Needs Playground Equipment	N/A	P.20
B.14	Inclusive Site/Building Furnishings	N/A	P.21
B.15.1	Other – South Door Operation	Push/Pull	
B.15.2	South Door Type/width	2 sets, Double/ outer: ½ TRN/ inner: opaque/ 1.50m (2x0.75m)	P.22.1
B.15.3	South Door Opening Direction	Inwards	
B.15.4	South Door Threshold Height	8cm	
B.15.5	North Door Operation	Push/Pull	
B.15.6	North Door Type/ Width	2 sets, Double/ outer: ½ TRN/ inner: opaque/ 1.50m (2x0.75m)	P.22. 2
B.15.7	North Door Opening Direction	Inwards	
B.15.8	North Door Threshold Height	3cm	
B.15.9	Front Yard Accessibility (West entry)	5 steps	P.22.3
B.15.10	Back Yard Accessibility (East entry)	Street level	P.22.4

(C) ELEVATOR INFORMATION

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	0	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door – Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	Yes	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	Yes	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	N/A	P.06
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	0	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Top Landing Tactile Warning Strip	N/A	
D.07	Inclined Plane (Slope-Length x Width)	N/A	
D.08	Inclined Plane Handrails information	N/A	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	N/A	
D.12	Bottom Landing Dimensions	N/A	
D.13	Bottom Landing Tactile Warning Strip	N/A	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 st Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 st Landing Handrails information	Both Sides/One Side/No	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



(E) SIGNAGE INFORMATION			
ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01.2
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	N/A	
E.05	Parking – Building Access Ramp Location	N/A	
E.06	Parking – Site Diagram	N/A	
E.07	Parking – Directional	N/A	
E.08	Parking – General Information	N/A	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	N/A	
E.11	Entrance/Reception – Bathroom Location	N/A	
E.12	Entrance/Reception – General Information	N/A	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.23
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	N/A	
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	No	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	N/A	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	N/A	
G.02	Public Side to Entrance	No	
G.03	Parking Area to Entrance	N/A	
G.04	Reception to Bathrooms	N/A	
G.05	Reception to other Interior Areas	N/A	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	TRN	Transparent