



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	1	P.01.1-3
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Wheel Chair	
A.05	Parking Area Access	N/A	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	N/A	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	N/A	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	1/ (2.20 x 5.00)	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-4
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	No	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	N/A	
A.14	Disabled Elevators	N/A	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	No	
A.19	Staircase Disabled Emergency Waiting Point	N/A	
A.20	Surface Materials – Parking Area	Cobble stone	P.10
A.21	Surface Materials – Entrance	Tiles	P.11
A.22	Surface Materials – Reception/Lobby	Tiles	P.12
A.23	Surface Materials – Corridors	N/A	P.13
A.24	Surface Materials – Other Indoor Spaces	Tiles	P.14.1-3
A.25	Surface Materials – Outdoor Gathering Spaces/ Pathways to church level	Stone/ Tiles/ Grass	P.15.1-4
A.26	Main Entry Vestibule	No	
A.27	Main Entry Door Operation	Push-Pull	P.16
A.28	Main Entry Door Type/ Single Door Width	Double/Opaque/65cm	
A.29	Main Entry Door Opening Direction	Inwards/Left+Right	
A.30	Main Entry Door Threshold Height	≥10mm/3 steps	
A.31	Wheelchair Accessible Entrance	No	P.17
A.32	Interior Doors (single door min/max width)	N/A	
A.33	Corridor Width (min/max width)	N/A	
A.34	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.35	Drain Covers Types	No	P.18
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	

**(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Church/ Listed	
B.02	Wheelchair Accessible Entrance (Door Operation)	See info in part A.27-A.30	P.17
B.03	WCA Entrance (Door Type/Single Door Width)	See info in part A.27-A.30	P.17
B.04	WCA Entrance (Door Opening Direction)	See info in part A.27-A.30	P.17
B.05	WCA Entrance (Threshold Height)	See info in part A.27-A.30	P.17
B.06	Service Counter Height/Knee Space (70cm/60cm)	1.12m/0cm	P.19
B.07	Service Counter Area (r ≥1.50m) or Dimensions	≥1.50m	
B.08	Wheelchair Spaces Available	N/A	P.20
B.09	Wheelchair Spaces (Row Location)	N/A	
B.10	Theater Stage/Playing Field Disabled Access	N/A	
B.11	Church Iconostasi Access	No	
B.12	Vestibule Dimensions (L x W)	N/A	
B.13	Vestibule Interior Door Operation	N/A	
B.14	Vestibule Interior Door (Type/ Single Door Width)	N/A	
B.15	Vestibule Interior Door Opening Direction	N/A	
B.16	Playground Accessibility	N/A	P.21
B.17	Special Needs Playground Equipment	N/A	P.22
B.18	Inclusive Site/Building Furnishings	N/A	P.23
B.19.1	Other: All outdoor buildings are scheduled for demolition according to the person in charge	Yes	P.24.1-3
B.19.2	Other: The Church is built on a rock, at a higher level from street. No WCA ramp and no easy access to it. Outdoor spaces are not easily WCA.		P.24.4-13

(C) ELEVATOR INFORMATION

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door – Wall Distance ≥150cm)	Yes	
C.06	Door – Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	Yes	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	Yes	
C.10	Wall Mirror Inside Cabin	Yes	

**(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Outdoor	P.06.4-6
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	6% - 4.00m x ≥1.60m	
D.08	1 st Inclined Plane Handrails	No	
D.09	1 st Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	No	
D.13	1 st Landing Handrails information	N/A	
D.14	1 st Landing Edge Protection	N/A	
D.15	2 nd Inclined Plane (Slope-Length x Width)	Varies 6%-13%/ 18.00m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	N/A	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	

**(E) SIGNAGE INFORMATION**

ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01.1-2
E.03	Parking – Disabled Parking Space Symbol	Yes	
E.04	Parking – International Accessibility Symbol	Yes	
E.05	Parking – Building Access Ramp Location	N/A	
E.06	Parking – Site Diagram	N/A	
E.07	Parking – Directional	N/A	
E.08	Parking – General Information	N/A	
E.09	Entrance/Reception – Site/Building Diagram	N/A	
E.10	Entrance/Reception – Directional	N/A	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.25.1-2
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	No	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other:	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	N/A	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAM

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

POSSIBLE ANSWERS		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial