



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Levels	1	P.01
A.02	Receptionist	N/A	
A.03	Qualified Singer / Languages Spoken	N/A	
A.04	Site Access	WC	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Yes	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	Not designated	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	N/A	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-3
A.11	Lifting Platforms	N/A	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	Not in Use	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	INA	
A.14	Disabled Elevators	N/A	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	No	
A.19	Staircase Disabled Emergency Waiting Point	N/A	
A.20	Surface Materials – Parking Area	Gravel	P.10
A.21	Surface Materials – Entrance	Tiles	P.11
A.22	Surface Materials – Narthex (Narthikas)	Tiles	P.12
A.23	Surface Materials – Nave	Tiles	P.13
A.24	Surface Materials – Iconostasi	Tiles	P.14
A.25	Surface Materials – Outdoor Gathering Spaces	Stone /Grass/ Concrete	P.15.1-3
A.26	Narthex/ Vestibule Information	N/A	
A.27	Narthex/ West Door Operation	Push/Pull	P.16
A.28	Narthex/ West Door Type/ Single Door Width	Double/ Opaque/ 58cm	
A.29	Narthex/ West Door Opening Direction	Inwards/ Left & Right	
A.30	Narthex/ West Door Threshold Height	≤10cm// 4.5cm	
A.31	Wheelchair Accessible Entrance	Yes (More info in part B)	P.17
A.32	Drain Covers Types	No	P.18
A.33	Indoor Light Intensity(LUX)	INA	
A.34	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Church/Listed/Arch. Mo	
B.02	North Entrance (Wheelchair Accessible)	No	P.19.1-2
B.03	North Entrance (Steps)	Yes	
B.04	North Entrance (Door Type/Single Door Width)	Double/ Opaque/ 44cm	
B.05	North Entrance (Door Opening Direction)	Inwards/ Left & Right	
B.06	North Entrance (Threshold Height)	9cm out and 7cm in	
B.07	South Entrance (Wheelchair Accessible)	No	P.20
B.08	South Entrance (Steps)	No	
B.09	South Entrance (Door Type/Single Door Width)	Double/ Opaque/ 56cm	
B.10	South Entrance (Door Opening Direction)	Inwards/ Left & Right	
B.11	South Entrance (Threshold Height)	≤10mm/ 4cm in and out	
B.12	Church Counter Height (100cm)	N/A	P.21
B.13	Church Candle Holder Height (100cm)	N/A	P.22
B.14	Wheelchair Spaces Available	N/A	P.23
B.15	Wheelchair Spaces (Row Location)	N/A	
B.16	Church Iconostasi Wheelchair Access	No	P.24.1-2
B.17	Vestibule Dimensions (L x W)	N/A	
B.18	Vestibule Interior Door Operation	N/A	
B.19	Vestibule Interior Door(Type/ Single Door Width)	N/A	
B.20	Vestibule Interior Door Opening Direction	N/A	
B.21	Inclusive Site/Building Furnishings	No	P.25
B.22.1	Other:	Yes	
	1- Kiosk/ Shop	Not easily accessible/ steps/ window at 100cm	P.26
	2- Gate House – not in use	Not easily accessible/ steps	P.27.1-2
	3- Movable Ramp – West Entrance Door	< 5% - 0.80c x 1.16m	P.28.1-2



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance Gate/ Outdoor	P.06.1-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - 32.0m x 1.00m concrete (+ 3.00m stone)	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	West Entrance/ Outdoor/ movable	
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	Inclined Plane - Width between Handrails	1.00m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

**(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	

(E) SIGNAGE INFORMATION

ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.19.1
E.03	Parking – Disabled Parking Space Symbol	N/A	
E.04	Parking – International Accessibility Symbol	N/A	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	N/A	
E.10	Entrance/Reception – Directional	N/A	
E.11	Entrance/Reception – Bathroom Location	N/A	
E.12	Entrance/Reception – General Information	N/A	
E.13	Inside Facility – Exhibition Area Labels	N/A	
E.14	Inside Facility – Site/Building Diagram	N/A	
E.15	Inside Facility – Directional	N/A	
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	No	
E.18	Facility's Outdoor Area – Site/Building Diagram	No	
E.19	Facility's Outdoor Area – Directional	No	
E.20	Other(Description)	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 st	1 st Floor
15	2 nd	2 nd Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

POSSIBLE ANSWERS		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial